



CONTRACTOR'S PRE-STARTUP CHECKLIST

Before equipment can be put through a performance check and warranty inspection by a factory authorized representative, the following items must be complete and in accordance with the Cambridge recommended installation procedures.

Failure to comply with these requirements will result in additional startup cost.

- ___ 1. Is the unit level and secure?
- ___ 2. Is there power to the unit?
- ___ 3. Is the control wiring complete between the unit and controller (if applicable)?
- ___ 4. Has the gas piping been installed and air bleed from piping ?
- ___ 5. Has any necessary ductwork been completed?
- ___ 6. Have all of the applicable options been installed and wired? (if applicable
- ___ 7. Are the start-up sheets and manuals still with the unit?
- ___ 8. Proper lift or ladders will be available at startup for technician access?

This form must be completed and returned to Faulkner/Haynes & Associates, Inc. before your scheduled startup date. Please allow 2 weeks' notice for scheduling startup.

Thank you for your cooperation!

Job site address _____

Signed _____ Date _____

Please return the form to Service@fha-hvac.com. If you have any questions please contact our service department at 919-781-8840 or email at Service@fha-hvac.com.